

EXHIBIT C

CONSTRUCTION HISTORY AND SCHEDULE

FINAL

**ALABAMA POWER COMPANY
WARRIOR RIVER PROJECT
FERC NO. 2165**

**APPLICATION FOR NEW LICENSE
FOR MAJOR WATER POWER PROJECT - EXISTING DAM**

EXHIBIT C

CONSTRUCTION HISTORY AND SCHEDULE

TABLE OF CONTENTS

1.0	INTRODUCTION	C-1
2.0	SMITH DEVELOPMENT.....	C-2
2.1	Construction History.....	C-2
2.1.1	Original Construction.....	C-2
2.1.2	Modifications/Additions to Project.....	C-2
2.2	Proposed Development	C-2
3.0	BANKHEAD DEVELOPMENT.....	C-3
3.1	Construction History.....	C-3
3.1.1	Original Construction.....	C-3
3.1.2	Modifications/Additions to Project.....	C-3
3.2	Proposed Development	C-3

FINAL

**ALABAMA POWER COMPANY
WARRIOR RIVER PROJECT
FERC NO. 2165**

**APPLICATION FOR NEW LICENSE
FOR MAJOR WATER POWER PROJECT - EXISTING DAM**

EXHIBIT C

CONSTRUCTION HISTORY AND SCHEDULE

1.0 INTRODUCTION

The Warrior River Hydroelectric Project consisting of the Smith and Bankhead developments was constructed between 1957 and 1963. Construction of the Smith development began in 1957 and was completed when the powerhouse entered into service in 1961. Construction of the Bankhead development began in 1961 and was completed when the powerhouse entered into service in 1963.

2.0 SMITH DEVELOPMENT

2.1 Construction History

2.1.1 Original Construction

This section is not applicable as this is not an application for an initial license.

2.1.2 Modifications/Additions to Project

In addition to routine maintenance, the Smith Development has undergone several improvements since its initial completion including, the rewinding of both generators and the replacement of the main power transformer and the governors.

2.2 Proposed Development

There are no plans for new development at this time.

3.0 BANKHEAD DEVELOPMENT

3.1 Construction History

3.1.1 Original Construction

This section is not applicable as this is not an application for an initial license.

3.1.2 Modifications/Additions to Project

The Bankhead development has also undergone several improvements in addition to its routine maintenance. APC has improved the powerhouse and other surrounding buildings. APC has also improved the wicket gate system and replaced the turbine runner with a more efficient runner as well as increased their ability to operate the project remotely. APC installed remote security cameras and upgraded a unit excitor in 2004, replaced a trash boom in 2002, replaced unit trash racks in 1999, and completed a unit upgrade in 1997.

3.2 Proposed Development

There are no plans for new development at this time.