

Blower Door

BET

Building Envelope Tightness

< 5ACH₅₀


 $\frac{(CFM_{50} \times 60)}{Volume}$

RITnah

Rough-in Total Leakage no air handler installed

≤ 3%

 $\frac{\textit{Total CFM}_{25}}{\textit{Floor Area Served}} \times 100$



RIT

Rough-in Total Leakage ≤ 4%

 $\frac{Total~CFM_{25}}{Floor~Area~Served}\times 100$

PCT

Post-construction Total Leakage ≤ 4%

 $\frac{Total~CFM_{25}}{Floor~Area~Served}\times 100$